



Polar diagram



Cone diagram



UGR diagram

Glare evaluation according to UGR										
ρ	Ceiling	70	70	50	50	30	70	70	50	50
ρ	Walls	50	30	50	30	30	50	30	50	30
ρ	Floor	20	20	20	20	20	20	20	20	20
Room size X Y	Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	18.3	19.6	18.6	19.9	20.1	19.2	20.5	19.5	20.8
	3H	19.6	20.8	19.9	21.0	21.3	20.7	21.9	21.0	22.2
	4H	20.0	21.2	20.4	21.5	21.7	21.3	22.5	21.7	22.7
	6H	20.3	21.4	20.7	21.7	22.0	21.7	22.8	22.1	23.1
	8H	20.4	21.4	20.8	21.7	22.1	21.9	22.9	22.2	23.5
	12H	20.4	21.4	20.8	21.7	22.1	21.9	22.9	22.3	23.6
4H	2H	19.0	20.1	19.3	20.4	20.7	19.7	20.8	20.0	21.1
	3H	20.4	21.4	20.8	21.7	22.0	21.3	22.3	21.7	22.7
	4H	21.0	21.8	21.4	22.2	22.6	22.1	22.9	22.5	23.3
	6H	21.4	22.1	21.8	22.5	22.9	22.6	23.3	23.0	24.1
	8H	21.5	22.2	21.9	22.6	23.0	22.7	23.4	23.2	23.8
	12H	21.5	22.2	22.0	22.6	23.0	22.9	23.5	23.3	24.3
8H	4H	21.2	21.9	21.7	22.3	22.7	22.2	22.9	22.6	23.7
	6H	21.7	22.3	22.2	22.7	23.2	22.8	23.4	23.3	24.3
	8H	21.9	22.4	22.4	22.8	23.3	23.1	23.6	23.5	24.5
	12H	22.0	22.4	22.5	22.9	23.4	23.2	23.6	23.7	24.1
12H	4H	21.2	21.9	21.7	22.3	22.7	22.2	22.8	22.7	23.7
	6H	21.8	22.3	22.2	22.7	23.2	22.8	23.3	23.3	24.3
	8H	22.0	22.4	22.4	22.9	23.4	23.1	23.5	23.6	24.5
Variation of the observer position for the luminaire distances S										
S = 1.0H	+0.1 / -0.2			+0.1 / -0.1						
S = 1.5H	+0.3 / -0.5			+0.2 / -0.3						
S = 2.0H	+0.5 / -0.9			+0.6 / -0.7						
Standard table	BK05			BK05						
Correction summand	2.8			4.0						
Corrected glare indices referring to 288lm Total luminous flux										

The UGR values are calculated in acc. with CIE Publ. 117. Spacing-to-Height-Ratio = 0.25